



CERTIFICATE OF PRODUCT CERTIFICATION

CERTIFICATE NO.: CQC24024425756

Valid from: Mar.27,2024

Valid until:long-term

NAME AND REGISTERED ADDRESS OF THE APPLICANT Yi Energy Technology (Zhejiang) Co.,Ltd
Room 109, Building 1, No. 55, Yifeng Road, Qiantang District, Hangzhou, Zhejiang P.R. China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER Yi Energy Technology (Zhejiang) Co.,Ltd
Room 109, Building 1, No. 55, Yifeng Road, Qiantang District, Hangzhou, Zhejiang P.R. China

NAME AND LOCATION OF THE FACTORY Yi Energy Technology (Zhejiang) Co.,Ltd
No.161,Yuancheng Road,Qiantang District,Hangzhou,Zhejiang P.R. China

PRODUCT NAME, MODEL AND SPECIFICATION Power Conversion System
PCS-100KM-L-Y1: DC side: the working voltage range 620~900V, the maximum DC current 178A;
Ac side: AC400V,50Hz, Max.159A, rated AC side power 100kW.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 34120-2017

TYPE OF CERTIFICATION SCHEMES Product Testing + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC33-461296-2018.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.
Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86 10 83886666
<http://www.cqc.com.cn>